



---

# IOWA STATE UNIVERSITY

## **Solar Power Plant and Substation Design**

---

*Final Presentation*

*Omer Karar, Maddy Lakomek, Madissen Lawrence, Jacob Miller, Brooke Nelson, Jenna Runge, Ashton Randolph, Zachary Zimmerman*

# Team Introduction

Omer Karar  
Madissen Lawrence  
Brooke Nelson  
Ashton Randolph  
Zach Zimmerman  
Jenna Runge  
Maddy Lakomek  
Jacob Miller



# Project Overview

# Problem Statement

---

- The United States has become more aware of its carbon footprint and is taking measures to minimize emissions. The greenhouse gas with the highest atmospheric emissions, carbon emissions, significantly impacts the environment.
- Local utilities have contracted Black & Veatch to implement a solar plant to increase their renewable energy sources. Our project will focus on Roswell, New Mexico, to implement a new generation system. We are designing a large-scale 60 MW utility solar power plant, along with a 34.5/115 kV substation, to provide more clean energy to the area.

# Project Requirements

---

- Design 80 MW DC/ 60 MW AC Solar Farm (Fall 2022)
- Select Location
- Select Panels
- Select Combiner Boxes
- Select Inverter Skids
- Voltage drop calculation
- The codes and Standards NED, IFC, UL
- Design layout of the Farm
- One-line diagram (Protection & Relaying)
- Design Substation to handle Output from Solar Farm (Spring 2023)

# User Needs

# Intended Users and Uses

---

- Anyone who uses electricity in New Mexico
  - Homeowners
  - Renters
  - Small businesses
- Utility companies

# Specific User Needs


---

- User: Utility
  - Values clean & consistent energy, efficiency
  - Needs:
    - Quality design
    - Proper location
      - High irradiance
      - Low humidity
      - Flat
      - Low cost land
- User: Electricity Consumer
  - Values consistent and reliable energy powering their homes
  - Needs:
    - Clean energy
    - Cheap energy
    - Reliability



# Components

# Components



# Array Parameter Tool

String Size			Electrical Rack Size			CB capacity			Array Design		
	Designer Choice	Portrait		41.1							
Location Dependent	Min Temp	-1.11 C	Datasheet	Module width	3.425 ft	Datasheet (STC)	mod/string Isc	11.26 A	Designer Choice	Racks per row	22 Designer Choice
Datasheet (STC)	Voc	53.61 V	Datasheet	module height	7.267 ft	NEC section	multiplier	1.25	Designer Choice	rows per Array	12
Datasheet (STC)	Ref temp	25 C	Designer Choice	Rack width	26 modules	Irr.	multiplier	1.25			
			Designer Choice	Rack height	2 modules		max Isc	17.59375 A	Designer Choice	Racks removed	0 Designer Choice
Datasheet	Temp Coeff of Voc	-0.0027 /C		Modules per rack			allowed current	400 A		Total Racks/Array	264
	Temp delta	-26.11		Rack width	89.050 ft	Designer Choice: 200, 400A etc.	is this disconnect A?			Total modules	13728
	temp correction	1.070497		Rack height	14.533 ft		strings per CB	22.73534636		Round down:	22
	Voc corrected	57.38934417					racks per CB	11	Datasheet (STC)	module capacity	480 W
Confirm possible with panel type chosen	Designer Choice: 600, 1000, 1500, 2000V	string voltage	1500 V		41.1		Total CB/Array	24		dc capacity	6589.44 kW
		String size	26.13725634		87.2		Round up:	24		inverter capacity	5000 kW
		string size	26	<b>Mod</b>	Q-Cells	480W			Designer Choice	ILR	1.317888 MVA
		Actual String Voltage	1492.122948	<b>CB</b>	Shaol	400A			Provided: Industry standard 1.3		
			<b>Inverter</b>	ABB	1500V/5MW						
	Input Information =							<a href="https://codes.iccsafe.org/content">https://codes.iccsafe.org/content</a>			
	Final =										

# Solar Panels

---



Q Peak Duo XL - G10.2

- 480W
- 53.61 Voc/11.26 Isc
- 44.81 Vmp/10.71 Imp
- 20.7% efficiency
- 12 year warranty

# Combiner Box

---



## Shoals 1500V Standard Combiner

- 1500 VDC
- Output Current of 400 A
- 70 lbs

# Inverter

---



ABB central inverter: PVS980-58

- 1500 V (DC) / 690 V (AC)
- Output Current of 4184 A
- 13,000 lbs

# Step Up Transformer

---



ABB medium voltage pad mounted solution

PVS980-MVP – 2.0 to 4.6 MVA


- 690V - 34.5kV Transformer
- Nominal output voltage ( $U_N(AC)$ ) 12 kV to 36 kV 2)
- Ambient temperature range (nominal ratings) 3) -25 °C to +50 °C

# CAD Layout



## 4 Major Decisions


- Orientation
- Tilt
- Row Spacing
  - Shading
  - Land Use
- Solar Farm Layout



<sup>2</sup> PV-3 ARRAY (M) DIMENSIONS


<sup>1</sup> PV-2 SOLAR PLANT ARRAY DESIGN  
NOT TO SCALE






1 ARRAY (A) COMPONENT LAYOUT (TYPICAL)  
PV-4 NOT TO SCALE

NOTE 1: ELECTRICAL DETAIL FOR ARRAY (A) IS SHOWN IN E-1 & E-2. EACH COMBINER BOX IS LABELED DCBXX




2 ARRAY (M) COMPONENT LAYOUT  
PV-4 NOT TO SCALE

NOTE 2: ELECTRICAL DETAIL FOR ARRAY (M) IS SHOWN IN E-3. EACH COMBINER BOX IS LABELED DCBXX




3 RACK/STRINGING DETAIL (TYPICAL)  
PV-3 NOT TO SCALE



4 RACK/STRINGING DETAIL  
PV-3 NOT TO SCALE





# Voltage Drop Calculations

# Normal Array Voltage Drop Calculations

JUMPER VOLTAGE DROP CALCULATIONS: ARRAY A - L (TYP)

DCB	Strings per Rack	IMP for String	String Length	String wire size	String Conductor resistance	String resistance	Voltage Drop of String	IMP for Jumper	Jumper Length	Jumper wire size	Jumper resistance	Jumper resistance	Voltage Drop of Jumper
DCB#-##	per rack	Amp	feet	AWG	Ohm/kft	Ohm	Volts	Amp	feet	AWG	Ohm/kft	Ohm	Volts
DCB1-01	2	10.7	85.7	10	2.000	0.332	3.668	21.4	490.00	6	0.808	0.766	16.945
DCB1-02	2	10.7	85.7	10	2.000	0.332	3.668	21.4	400.95	6	0.808	0.627	13.866
DCB1-03	2	10.7	85.7	10	2.000	0.332	3.668	21.4	311.90	6	0.808	0.488	10.786
DCB1-04	2	10.7	85.7	10	2.000	0.332	3.668	21.4	222.85	6	0.808	0.348	7.707
DCB1-05	2	10.7	85.7	10	2.000	0.332	3.668	21.4	133.80	6	0.808	0.209	4.627
DCB1-06	2	10.7	85.7	10	2.000	0.332	3.668	21.4	44.75	6	0.808	0.070	1.548
DCB1-07	2	10.7	85.7	10	2.000	0.332	3.668	21.4	44.75	6	0.808	0.070	1.548
DCB1-08	2	10.7	85.7	10	2.000	0.332	3.668	21.4	133.80	6	0.808	0.209	4.627
DCB1-09	2	10.7	85.7	10	2.000	0.332	3.668	21.4	222.85	6	0.808	0.348	7.707
DCB1-10	2	10.7	85.7	10	2.000	0.332	3.668	21.4	311.90	6	0.808	0.488	10.786
DCB1-11	2	10.7	85.7	10	2.000	0.332	3.668	21.4	400.95	6	0.808	0.627	13.866

$$V_d = \frac{2LR_2I}{1000}$$

Where:

$V_d$  = voltage drop over circuit length (volts)

$L$  = length of circuit (ft)

$R_2$  = resistance of conductor from Equation (ohm/kft)

$I$  = maximum power current of circuit (amps)

Requirement Threshold = 5%

Hand Calculation Check - Design Document 3.2.2.4

DCB	No. of Rack Inputs	IMP for DCB circuit	Feeder length	Feeder wire size	Feeder resistance	Feeder resistance	Voltage drop for feeder	Voltage drop for feeder	Voltage drop for circuit	VMP for circuit	Voltage drop for circuit
DCB#-##	#	Amp	feet	kcmil	Ohm/kft	Ohm	Volt	per cent	Volt	Volt	per cent
DCB1.1	11	235.40	641	600	0.035	0.044	10.653	0.91%	48.338	1165.00	4.15%
DCB1.2	11	235.40	641	600	0.035	0.044	10.653	0.91%	48.338	1165.00	4.15%
DCB2.1	11	235.40	612	600	0.035	0.042	10.171	0.87%	48.177	1165.00	4.14%
DCB2.2	11	235.40	612	600	0.035	0.042	10.171	0.87%	48.177	1165.00	4.14%
DCB3.1	11	235.40	583	600	0.035	0.040	9.689	0.83%	48.016	1165.00	4.12%
DCB3.2	11	235.40	583	600	0.035	0.040	9.689	0.83%	48.016	1165.00	4.12%
DCB4.1	11	235.40	553	600	0.035	0.038	9.190	0.79%	47.850	1165.00	4.11%
DCB4.2	11	235.40	553	600	0.035	0.038	9.190	0.79%	47.850	1165.00	4.11%
DCB5.1	11	235.40	524	600	0.035	0.036	8.708	0.75%	47.689	1165.00	4.09%
DCB5.2	11	235.40	524	600	0.035	0.036	8.708	0.75%	47.689	1165.00	4.09%
DCB6.1	11	235.40	494	600	0.035	0.034	8.210	0.70%	47.523	1165.00	4.08%
DCB6.2	11	235.40	494	600	0.035	0.034	8.210	0.70%	47.523	1165.00	4.08%
DCB7.1	11	235.40	494	600	0.035	0.034	8.210	0.70%	47.523	1165.00	4.08%
DCB7.2	11	235.40	494	600	0.035	0.034	8.210	0.70%	47.523	1165.00	4.08%
DCB8.1	11	235.40	524	600	0.035	0.036	8.708	0.75%	47.689	1165.00	4.09%
DCB8.2	11	235.40	524	600	0.035	0.036	8.708	0.75%	47.689	1165.00	4.09%
DCB9.1	11	235.40	553	600	0.035	0.038	9.190	0.79%	47.850	1165.00	4.11%
DCB9.2	11	235.40	553	600	0.035	0.038	9.190	0.79%	47.850	1165.00	4.11%
DCB10.1	11	235.40	583	600	0.035	0.040	9.689	0.83%	48.016	1165.00	4.12%
DCB10.2	11	235.40	583	600	0.035	0.040	9.689	0.83%	48.016	1165.00	4.12%
DCB11.1	11	235.40	612	600	0.035	0.042	10.171	0.87%	48.177	1165.00	4.14%
DCB11.2	11	235.40	612	600	0.035	0.042	10.171	0.87%	48.177	1165.00	4.14%
DCB12.1	11	235.40	641	600	0.035	0.044	10.653	0.91%	48.338	1165.00	4.15%
DCB12.2	11	235.40	641	600	0.035	0.044	10.653	0.91%	48.338	1165.00	4.15%

<b>Average of worst-case DCB voltage drop:</b>	<b>4.11%</b>
--	--------------

# Small Array Voltage Drop Calculations

DCB	Strings per Rack	IMP for String	String Length	String wire size	String Conductor resistance	String resistance	Voltage Drop of String	IMP for Jumper	Jumper Length	Jumper wire size	Jumper resistance	Jumper resistance	Voltage Drop of Jumper
DCB#-##	per rack	Amp	feet	AWG	Ohm/kft	Ohm	Volts	Amp	feet	AWG	Ohm/kft	Ohm	Volts
DCB13.x-01	2	10.7	85.7	10	2.000	0.332	3.668	21.4	396	6	0.808	0.619	13.695
DCB13.x-02	2	10.7	85.7	10	2.000	0.332	3.668	21.4	310	6	0.808	0.485	10.721
DCB13.x-03	2	10.7	85.7	10	2.000	0.332	3.668	21.4	224	6	0.808	0.350	7.746
DCB13.x-04	2	10.7	85.7	10	2.000	0.332	3.668	21.4	138	6	0.808	0.216	4.772
DCB13.x-05	2	10.7	85.7	10	2.000	0.332	3.668	21.4	52	6	0.808	0.081	1.798
DCB13.x-06	2	10.7	85.7	10	2.000	0.332	3.668	21.4	43	6	0.808	0.067	1.487
DCB13.x-07	2	10.7	85.7	10	2.000	0.332	3.668	21.4	468	6	0.808	0.732	16.185
DCB13.x-08	2	10.7	85.7	10	2.000	0.332	3.668	21.4	382	6	0.808	0.597	13.210
DCB13.x-09	2	10.7	85.7	10	2.000	0.332	3.668	21.4	296	6	0.808	0.463	10.236
DCB13.x-10	2	10.7	85.7	10	2.000	0.332	3.668	21.4	210	6	0.808	0.328	7.262
DCB13.x-11	2	10.7	85.7	10	2.000	0.332	3.668	21.4	74	6	0.808	0.116	2.559
DCB14.1-01	2	10.7	85.7	10	2.000	0.332	3.668	21.4	396	6	0.808	0.619	13.695
DCB14.1-02	2	10.7	85.7	10	2.000	0.332	3.668	21.4	310	6	0.808	0.485	10.721
DCB14.1-03	2	10.7	85.7	10	2.000	0.332	3.668	21.4	224	6	0.808	0.350	7.746
DCB14.1-04	2	10.7	85.7	10	2.000	0.332	3.668	21.4	138	6	0.808	0.216	4.772
DCB14.1-05	2	10.7	85.7	10	2.000	0.332	3.668	21.4	52	6	0.808	0.081	1.798
DCB14.1-06	2	10.7	85.7	10	2.000	0.332	3.668	21.4	43	6	0.808	0.067	1.487
DCB14.1-07	2	10.7	85.7	10	2.000	0.332	3.668	21.4	74	6	0.808	0.116	2.559
DCB15.1-01	2	10.7	85.7	10	2.000	0.332	3.668	21.4	396	6	0.808	0.619	13.695
DCB15.1-02	2	10.7	85.7	10	2.000	0.332	3.668	21.4	310	6	0.808	0.485	10.721
DCB15.1-03	2	10.7	85.7	10	2.000	0.332	3.668	21.4	224	6	0.808	0.350	7.746
DCB15.1-04	2	10.7	85.7	10	2.000	0.332	3.668	21.4	138	6	0.808	0.216	4.772
DCB15.1-05	2	10.7	85.7	10	2.000	0.332	3.668	21.4	52	6	0.808	0.081	1.798
DCB15.1-06	2	10.7	85.7	10	2.000	0.332	3.668	21.4	43	6	0.808	0.067	1.487
DCB15.1-07	2	10.7	85.7	10	2.000	0.332	3.668	21.4	74	6	0.808	0.116	2.559
DCB15.1-07	1	10.7	13.7	10	2.000	0.053	0.586	10.7	74	6	0.808	0.116	1.280
DCB13.1	11	235.40	106.5	600	0.035	0.007	1.770	0.15%	43.930	1165.00	3.77%		
DCB13.2	11	235.40	106.5	600	0.035	0.007	1.770	0.15%	43.930	1165.00	3.77%		
DCB14.1	7	235.40	69.5	600	0.035	0.005	1.155	0.10%	23.203	1165.00	1.99%		
DCB15.1	9	235.40	69.5	600	0.035	0.005	1.155	0.10%	25.901	1165.00	2.22%		

Average of worst-case DCB voltage drop:

2.94%

# Bill of Materials



# Wiring Materials & Components

"Wiring" Material	Normal Array(ft)	Small Array (ft)	Total length (ft)	Cost (\$/ft)	Total (\$)
10 AWG Al THWN	90500	8941	99,441.00	\$1.40	\$139,217.40
6 AWG Al THWN	130488	10430	140,918.00	\$1.40	\$197,285.20
600kcmil Al THWN	327072	704	327,776.00	\$6.42	\$2,104,321.92
<b>Sub Total(\$)</b>					\$2,440,824.52

Components	Amount		Cost per (\$)	Total (\$)
Inverters	13		\$303,763.00	\$3,948,919.00
Combiner Boxes	292		\$250.00	\$73,000.00
Solar Panels	166667		\$460.00	\$76,666,820.00
<b>Sub Total(\$)</b>				\$80,688,739.00

# Racking Material

Racking Material	Part #	Qty		Cost per (\$)	Total (\$)
Ground Rail, 172IN, SILVER	232-02542	1489	112 per bundle	\$122.29	\$182,089.81
Ultra Rail MID Clamp, Silver	242-02070	166660		\$4.43	\$738,303.80
Universal End Clamp	242-02215	333320		\$6.28	\$2,093,249.60
Bonding Pipe Clamp Assembly for 1-1/2 IN	242-09004	333320		\$7.48	\$2,493,233.60
Ground Rail End Cap, Black	232-01043	333320		\$2.87	\$956,628.40
Ground Lug Assembly, 6-12 AWG	242-02101	3205		\$6.01	\$19,262.05
5EXT-8, Single Socket Tee, 1-1/2IN, AL-MG	172-05818	192300		\$33.37	\$6,417,051.00
17-8, Single Adjustable Socket Tee, 1-1/2IN, AL-MG	172-05803	192340		\$30.87	\$5,937,535.80
62-8, Plug End, 1-1/2IN, AL	172-05808	205120		\$7.85	\$1,610,192.00
Junction Box	242-01104	3205		\$35.11	\$112,527.55
<b>Sub Total(\$)</b>					\$20,560,073.61
<b>Total (\$)</b>					\$103,689,637.13

# Cost Analysis


No Axis Tracking										
\$13/kW										
Installation Cost		O+M/yr	Inflation Rate	Yearly Revenue						
\$ 103,689,637.13		\$ 585,000.00	3.22%	\$ 11,510,246.23						
\$1767/kW										
Cash Flow										
Year 0	Year 1	Year 2	Year 3	Year 4	Year 5	Year 6	Year 7	Year 8	Year 9	Year 10
\$ (103,689,637.13)	\$ 10,925,246.23	\$ 11,277,039.16	\$ 11,640,159.82	\$ 12,014,972.96	\$ 12,401,855.09	\$ 12,801,194.83	\$ 13,213,393.30	\$ 13,638,864.56	\$ 14,078,036.00	\$ 14,531,348.76
Present Value										
Years	Installation Cost	O+M	Revenue	Profit						
10	\$ (103,689,637.13)	(\$4,934,606.35)	\$ 126,522,110.71	\$ 17,897,867.22						

# Moving Forward

# Substation Design

---

- Substation Key Plan
- Grounding System
- Cable Trenching Calculations
- Cables, Bus, Breaker, Switches, Transformers
- Monitoring and Protection



# Questions?