Demo: Progression of Work

115kV/34.5kV Solar Power Plant and Substation Design

Work Completed


60 MW Solar Plant

- Part Selection
- Array Parameters
- Voltage Drop Calculations
- Solar Farm Layout CAD
- Wiring
- Racking
- Cost Estimate


115kV/34.5kV Substation

- One Line
- Three Line
- Key Plan
- Conduit Plan
- Trench Plan
- Grounding Grid
- DC Battery Calculations
- Lightning Protection
- Bus Calculations
- AC Load Calculations
- Cost Estimate
- ETAP Simulation Studies

Solar Farm Equipment Layout - V1



Voltage Drop with Original Design = 10%




Why We Made Changes to Solar Design - Voltage Drop


- Max Allowable Voltage Drop = 5%
- With old design the jumper length was causing the high voltage drop
- Decreased the jumper length by moving the combiner boxes in the center of the rows
 - Primary initial concern with the movement was maintenance but the spacing between rows is large enough to comfortable fit a maintenance vehicle
- Lower voltage drop along feeder due to increased wire size
- Final Voltage Drop = 4.05%



Solar Farm Final Version



Substation One Line V1– Sectionalized Bus



Substation One Line Final

